


AURORA PUMP

BULLETIN 650A/Rev. F 650 SERIES SINGLE STAGE NON-CLOG PUMPS

CAPACITIES TO 2000 G.P.M. HEADS TO 240 FEET TEMPERATURES TO 250°F. DISCHARGE SIZES 3" AND 4"



INTRODUCTION NON-CLOG PUMPS

The population explosion along with a broader understanding of the water pollution problem has brought about the need for more and better sewage treatment facilities. The installations of today and tomorrow demand more economical and reliable sewage pumping equipment. Longer life has become essential to pump performance. Aurora Pump recognizes this need, and with this bulletin offers the 650 Series of the medium duty horizontal and vertical pumps as our solution to your pumping problems.

of the installation is not possible.

meed, and with this bulletin offers the 650 Series of the medium duty horizontal and vertical pumps as our solution to your pumping problems.

MODELS 651A are horizontally baseplate mounted with a driver flexibly coupled to the pump. This easy to service design is recommended where floor space is readily available or where flooding where flooding of the installation

MODELS 653A and 654A are vertically mounted with an elevated driver coupled directly to the pump (Model 653A thru a flexible coupling). 653A-654A are popular for installations where floor space is limited and flooding is marginal.

POSITIVE LUBRICATION OF ALL BEARINGS

Power Series 5 Illustrated With Back to Back Thrust Bearings

10

QUICK REFERENCE 650 SERIES FEATURE

SELECTOR

STANDARD

All iron fitted pump construction Regreaseable bearings Double row outboard thrust bearing Single row inboard radial bearing Hardened stainless steel (450 min. Brinell) shaft sleeve (pumps with packing) Leakage accumulator packing gland (Model 652A-653A) Impeller clearance adjustment Taper shaft fit at impeller Carbon steel shaft and impeller key Front or back impeller pull out Non-clog impeller Dynamically balanced impeller Suction elbow w/hand hole (Model 652A-653A-654A) Tangential discharge casing Hydrostatic test all pumps Interwoven graphite/Teflon lubricated acrylic yarn packing Lantern ring Discharge position No. 1 Right hand (cw) pump rotation Gasket sealed pump shaft Coupling Guard (Model 651A)

is possible. The driver is remote.

1-1/2" to 3" sphere capacity

OPTIONAL

Removable split packing box

Stainless steel case wear ring

Stainless steel impeller wear ring


Single mechanical seal Stainless steel shaft External stuffing box piping with filter or valve Automatic stuffing box grease seal lubricator Spacer type coupling (Model 651A Flexible shaft drive with or without guard (Model 652A only) Water Seal Unit Assembly (See Bulletin 680) Constant liquid level system (Apco-Matic Variable Speed — See Bulletin 700) Certified test report - witnessed or unwitnessed (clear water) Special alloy pump construction Alternate discharge positions Alloy shaft sleeve (standard with mechanical seal) Double mechanical seal (std. 654A) Suction increasing elbow with clean out (Models 652A-653A-654A) Left hand (ccw) pump rotation






SPECIAL PUMP FEATURES


Efficient tangential discharge. MODELS 651A are horizontally baseplate mounted with a driver flexibly coupled to the pump. SUPPORT of various pump components is important. Inadequate mounting designs impose unnecessary stress and strain on the entire pump and installation. Vibration results. AURORA tangential pumps designed to provide the best available component support. HORIZONTAL 651A UNITS are supported at both pump and coupling end. This, with tangential discharge support, provides protection against pipe strain and maintains casing support when the drive end of the pump is removed for servicing. The rear support foot greatly simplifies coupling alignment and is an important Aurora feature. On VERTICAL 653A UNITS, the steel motor base has a tangential pump registered fit at the motor end and is fastened to a separate pump adapter. This exclusive arrangement assures alignment and concentrates loads on the separate pump adapter eliminating strain and misalignment of the bearing housing. On 652A-653A-654A UNITS the steel base provides a rigid support for the complete pump unit. 654A is close coupled.




OPTIONAL EQUIPMENT AND DIMENSIONS

SPLIT PACKING BOXES separate vertically through the packing insert to simplify packing replacement and shaft sleeve inspection. The insert halves are doweled, register aligned and gasketed to prevent leakage. Only six bolts need be removed to disassemble the insert from the pump assembly. DOUBLE MECHANICAL SEALS must be recommended for gritty or abrasive applications. Seal faces are protected by clear water under pressure, injected directly into the seal cavity. The seal box design allows speedy seal maintenance. Single mechanical seals are available. LEAKAGE ACCUMULATOR for vertical pump models with packed stuffing boxes collects seepage for easy drain off. The gland halves are dowel aligned.





	651A-652A-653A-654A — DIMENSIONS — PUMP *Add 2" w/Frame 284 HPH or larger									651A - DIMENSIONS - BASE																	
PU	MP:	SIZE		PU	MP WEIG	нт									CF					X				The second			188
DISCH.	SUCT.	CASE	PWR. SER	651A	652A	653A	A	0	u	×	٧	ı	651A	652A	653A	654A	VD	VE	vv	FRAMES	BASE	на	нв	нр	на	HL	BASEWT
-	Ι,	,	30	192	257	291	17	6-1/4	1-1/4		3	5	26-5/9	39-7/8	43-1/2	26/9/16	16-174	7-3/4	5-1/2	56-2157	7	20-1/2	36-172	9.1/4	3	10-5/16	92
	ľ				-															254T	- 0	20-1/2	42:1/2	9-1/4	3	10-5/16	106
				-68	100	200		200			V412	444		41.5/8	45-1/4		17-5/16	7-3/4	5-1/2	56:2151	7	20-1/2	36.1/2	9-1/4	э	12-3/16	92.
3	1	9	эс.	228	303	337	17	6-174	3-1/4	1	4:1/16	0-1/8	28-3/8	41-5/8	49-1/4	28-5716	17-5/10	7-3/4	3-1/4	2547	n	20-1/2	42-1/2	8-1/4	3	12-3/16	106
				-	100	100		1000			11.5	100		41.7/8		28.9/18	18	6-15/16	6.1/2	56-2157	7	20-1/2	36-1/2	9-1/4	-3	12-3/16	92
. *	1	7	ж	207	293	327	17	0-1/4	1/1//4	100	4-1/2	5-3/8	18-3/6	41-7/8	45-1/2	28-9/10	10	6-16/1B	0-172	2547	0	20-1/2	42:1/2	9.1/4	3	12:3/16	106
				100						1.50		1000		3	44.5/8	27-11/16	17-3/4	6-15/16	6-1/2	56-2157	7	20:1/2	36-1/2	9-1/4	. 3	11-7/16	92
*	1	34	ж	232	318	351	17	5-174	1.1/4	0.1/4	4.174	2/12/16	27.1/2	*	44.5/8	23-11/16	17/0/4	N-15/16	0-172	2541	- 11	20-1/2	42:1/2	5-1/4	2	11:7/15	106
																			6.1/2	1827-2137	9	20-1/2	48/1/2	14	3	-2-15/16	121
1	4	38	AC	242	328	361	17	11.	313/4	10	6-3/16	21778	28-7/8	42:3/1	46-1/8	29-3716	19-11/16	6-19/16	8-17-2	2157-2867	10	20-1/2	56 1/2	14	3	2/15/16	140
	i.																	6-15/10	6-1/2	1821-2151	-9	20.1/2	48 1/2	16-1/2	3	5/8	121
1	1	12	40	317	402	435	17	13-1/2	1-1/4	10-1/2	8/3/4	9	28.7/8	42-3/8	46-1/8	29-3/16	19/3/9	6-15/16	0:1/2	254T-285T	10	20-1/2	56-1/2	16-1/2	з	578	140
	Ī											. 1				20.20				2131-2561	13	26-3/4	64/1/2	17:1/2	4	- 5/0	256
4	A	12	SE	327	412	445	17	13:1/2	2-3/6	10-1/2	6-1/4		39-7/1	53-3/8	*56-15/16	30-3/8	19-3/4	6-15/16	6-1/2	28415-3261	14	26-3/4	72/1/2	17:1/2	4	- 5/8	287
		14	SE	797	1060	1292	24	15-1/4	2.3/8	10.1/2	6.2/16	10:1/4	39-1/2	67-3/9	*60-15/16	34-3/8	24-1/16	9-7/8	. 16	213T-365T	14	26-3/4	72:1/2	19-174	.4	-1-9/16	287.
			SF.		1000	12.00		1000												40415-4441	18	29-1/8	82-1/2	19-1/4	4	1-9/16	491



- 1 LIFTING EYE tap in shaft end simplifies disassembly.
- 2 EXTERNAL SHAFT ADJUSTMENT provides for renewing impeller clearance and maintaining pump efficiency.
- 3 DOUBLE ROWTHRUST BEARINGS are added protection for high loads. Average bearing life is 10 years.
- 4 WATER SLINGER, and grease seals protect both bearings from moisture.
- 5 LEAKAGE ACCUMULATOR GLAND option to siphon off packing leakage.
- 6 STUFFING BOXES are machined for mechanical seals or packing. Either may be used without modification.
- **7** GASKETS protect shaft from pumped liquid corrosion and contamination.
- 8 IMPELLER VANES brought well into the inlet eye to pick up liquid early and to minimize clogging.
- 9 GREASE LUBRICATION purges old grease from both bearings.
- 10 RUGGED SHAFT with taper for easy impeller removal and minimum deflection.
- 11 HARDENED STAINLESS STEEL SLEEVE on packed pumps is securely key locked to the shaft.
- 12 .002 MAXIMUM SHAFT DEFLECTION at stuffing box face extends packing and mechanical seal life.
- 13 BACK PULLOUT DESIGN for pump maintenance, does not disturb suction or discharge piping.
- 14 SNAP RING groove is provided for a snap ring to aid in sleeve removal during preventative maintenance period.
- 15 STEEL IMPELLER KEY, capscrew and washer secures impeller to shaft.
- 16 NEMA STANDARD "HP" mounting face and shaft extension motors.
- 17 LARGE ACCESS OPENINGS provide adequate visibility and working room.
- 18 OVAL CLEANOUTS are large, HAND SIZE and located to provide visibility and accessibility to the impeller blades and the casing cutwater.
- 19 DISCHARGE flanges can be located in 45° increments for 8 different positions. (suction in 90°-vert. pumps)
 20 STANDARD GAUGE TAPS are conveniently located at both the discharge and suction flange openings.
 21 STANDARD DRAIN TAPS are located conveniently in the adapter

bracket, suction elbow, and casing.

ENGINEERING SPECIFICATIONS

4		POWER SERIES				THE RESERVE OF THE PARTY OF THE	POWER SERIES			
AREA	DESCRIPTION	30	4C	SE/SF	AHEA	DESCRIPTION	3C	4C	SE/SF	
Ī	Sruffing Box Bore Diameter		3-9/32	3-9/32	4/25/32	2 4 3/4 25/32 7/16	Dig. at Impeller (Average of Taper)	1.7/16	1/7/16	2/1/4
	Stuffing Box Depth		2/3/4	2/3/4	3-1/2		Diameter at Shaft Sleve	1.7/8	1.7/8	3-1/4
	Ourside Dia , Sileeve for Facking		2-1/2	2:1/2	3-374		Diameter Between Bearings (Max. Shaft Dia.)	2:3/8	3-5/16	4-1/8
	Total Number of Packing Hings With Lantern Ring	PACKING	5	5	5		Diameter at Coupling End	1.174	1.1/4	2-3/8
G BOX	No. of Rings in Front. of Lantern Ring	PAC	2	2.	2		Max Deflection at Stuffing Box Face	.002	002	002
-	Packing Size		3/8	3/8	1/2		Bearing No. Unboard	6310	6311	6317/58
STUFFING	Width of Lacture Ring		5/8	5/8	3/4		Radials			21317
	Distance from Bux to Nearest Obstruction		2:15/16	2-15/16	2/3/4		Bearing No. (Clubboard Thrust)	3310	3309	7315*
	Dia of Mech. Seal (Bore)		3-9/32	3.9/32	4/25/32		Bearing Centers	7.9/32	7-3/4	12-11/1
	Length of Mechanical Seal	SEAL	3/3/41	3.174	4-7/16		Minimum Life of Bearing			
	Outside Dia , Sleeve for Mechanical Seat	2	2-1/4	2/1/4	3-5/8		Under Worst Conditions of Load	2 Years	2 Years	2 Years

Furnish and install as shown on the plans, Aurora Model (Horizontal-651A) (Vertical-653A Flexible Coupled) (Vertical-652A Open Shaft) (Vertical-654A-Close Coupled) type Non-Clog Centrifugal pump. The pump shall be capable of delivering a capacity of GPM when operating against a total dynamic head of feet. The pump shall also deliver a . GPM when operating maximum of against a head of . . . feet. The minimum shut-off head acceptable will be feet.

The pump shall operate at a maximum RPM. A unit operating at a lesser rotative speed will be considered, but in no event will a pump operating at more than the maximum speed specified be acceptable.

The pump casing shall be of the tangential design and will be constructed of cast iron and shall be of sufficient thickness to withstand stresses and strains at full operating pressures. Casings shall be subject to a hydrostatic pressure test of 125 lbs. A handhole is to be provided in the 3" and 4" casings for clean out purposes. The casing design shall allow front or rear impeller pullout.

The bearing housing is to be of cast iron and shall be furnished with a set of regreaseable bearings for both radial and thrust loads. A double row thrust bearing is to be provided to ensure maximum bearing life under extreme thrust loads. The bearings shall have an average life of 100,000 hours and shall be mounted in a machined, moisture and dust proof housing. The housing is to have a register fit and then bolted to the pump casing to insure permanent alignment.

An extra deep (split) packing box simplifying packing replacement and shaft sleeve inspection is to be provided and must be so arranged with a lantern ring for either grease lubrication or tapped connections for water sealing from an outside source. A 3/8" drain opening must be provided to facilitate removal of lubricating liquid.

The impeller to be of cast iron and shall be capable of passing a maximum sphere inches. The impeller shall be size of dynamically balanced before assembly into the pump and shall be securely fastened to the shaft by means of a steel key and impeller locknut. Axial adjustment of the impeller is to be external and a minimum clearance of . thousands should be maintained between the impeller and suction wearplate. The pump shaft shall be constructed of high grade carbon steel having a tapered impeller extension and accurately machined. The minimum diameter acceptable between bearings will be 2-3/8 inches. The pump shaft shall be protected from wear by a corrosion and wear resisting hardened stainless steel shaft sleeve having a 450 minimum Brinell hardness. An "O" ring type gasket must be provided between the impeller hub and the shaft sleeve to prevent pumped liquid from corroding the shaft

MODEL 651A HORIZONTAL

The pump and motor shall be mounted on

Case working pro Suction pressure Temperature Par Temperature Me	essure cking ch. Seat	150 PSI 125 PSI 125 PSI 250° 225° 1775 RPM				
DESCRIPTION	FITTED	MATERIAL OF CONSTRUCTION				
Impetier.	tron	Cast Iron ASTM A48				
Gland	Iron	Cast Iron ASTM A48				
Packing	Iron	Graphite/Tellon Lubricated Acrylic Yarn				
Insert	Iron	Cast Iron ASTM A48				
Lant Ring	fron	Teflon				
1 A-100 (100 (100 (100 (100 (100 (100 (100	Stainless	Stainless Steel AISI 316				
Sleeve (Pack)	Iron	Hard, Stri. Steel AISt 4400				
Sleeve (Seal	Iron	Bronze ASTM 862				
Sleeve (Seal)	Stainless	Stainless Steel AISI 316				
Impeller Screw	Iran	Steel SAE Grade 5				
Shaft	Iron	Steel SAE 1045				
Frame	Iron	Cast Iron ASTM A48				
Casing	Iron	Cast Iron ASTM A48				
Cover	Iron	Cast Iron ASTM A48				

a common (steel) (steel drip rim) base. Alignment shall be checked in accordance with the Standards of the Hydraulic Institute after installation and there shall be no strain transmitted to the pumps.

Supports

MODEL 652A VERTICAL OPEN SHAFT, 653A VERTICAL FLEXIBLE COUPLED AND 654A CLOSE COUPLED VERTICAL PUMPS

The pump shall be supported by a fab. steel pedestal base. The pedestal shall have openings large enough to permit access to the suction line. An optional handhole of not less than 3" in diameter must be provided in the suction elbow on 3" and 4" pumps. The pedestal must be of sufficient height so that the suction elbow will not touch the floor or foundation upon which it stands.


Vertical flexible coupled pumps shall be furnished with a fab. steel motor bracket which is to be bolted to a separate pump adapter. The motor bracket must be machined with a register fit to insure proper alignment of motor shaft and pump shaft. 654A is coupled directly to the motor shaft extension.

Vertical open shaft pumps are to be driven through flexible shafting with dia. tubing, and intermediate bearings. Shafting must be of sufficient size to transmit required horsepower and must be provided with a slip spline which will permit removal of the pump rotating assembly without removing any section of intermediate shafting, bearings, suction or discharge piping (... sections required).

The Engineering Specification has been condensed from a very comprehensive specification. Additional information is available from any Aurora Pump Sales Office. Aurora Pump reserves the right to make revisions to its products and their specifications, and to this bulletin and related information without notice.

NOTE: Aurora Pump reserves the right to make revisions to its products and their specifications, and to this bulletin and related information without notice.

- Your Authorized Local Distributor -







MARKETING & SALES:

for your local Distributor.

800 AIRPORT ROAD . NORTH AURORA, ILLINOIS U.S.A. . 60542 PHONE: (630) 859-7000 U.S.A./CANADA FAX: (630) 859-7060 WORLDWIDE FAX: (630) 859-1226

WEB; www.ourorspump.com EMAIL: ourors_info@pentairpump.com

AURORA MFG. PLANT: 800 AIRPORT ROAD . NORTH AURORA ILLINOIS U.S.A. . 60542 SALES OFFICES IN ALL MAJOR CITIES AND COUNTRIES Refer to "Pumps" in yellow pages of your phone directory